


CERTIFICATE

Certificate holder	LUX Elements GmbH & Co KG An der Schusterinsel 7 51379 Leverkusen GERMANY
Product	Barrier-free products
Type, Model	LUX ELEMENTS® - Shower receptor units TUB 1500 x 1500 mm
Testing basis	DIN 18040-1:2010-10 DIN 18040-2:2011-09 Certification scheme barrier-free designs, buildings and products (2015-07)
Mark of conformity	
Registration No.	P1B037
Valid until	2026-03-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

ANNEX

Certificate P1B037 dated 2023-01-12

Technical Data LUX ELEMENTS® - TUB shower receptor units $\geq 1500 \times 1500$ mm

Shower receptor units that set flush with the sub-base and can be tiled, consisting of hard foam carrier plates with an incline, sealed on the upper side and built-in, sealed drainage attachment (DN 50):

- height of carrier plate 30/45 mm (middle/outside)
- center minimum height 30 mm
- built-in, sealed drainage attachment
- integral incline of 45 mm and 30 mm
- pressure resistance 0.1 N/mm²

LUX ELEMENTS®-BAS (vertical shower waste):

- waste water pipe DN 50 vertical with removable stench trap

LUX ELEMENTS®-BAW (horizontal shower waste):

- waste water pipe DN 50 with removable stench trap

**Testing laboratory/
Inspection body** Lautsch-Wunderlich, Dagmar
Podbielskiallee 19
14195 Berlin
GERMANY

Test report(s) Report dated 2023-01-09

